


Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. JS/PHE/SD/B/2026-27/02 Dated: 01/04/2026

It is certified that an inspection team headed by Sh. Ashok Kumar, Junior Engineer (Name of Officers with designation) from Department of Jal Shakti (PHE), UT of J&K PHED inspected the SWISS INTERNATIONAL SCHOOL, DRUDHU BHADERWAH, DODA (Name & Address of the school) on 28.03.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no 1290,1291 dated 30-03-2026 of Water Testing Laboratory, Bhaderwah (PHED Lab) certified that the SWISS INTERNATIONAL SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 30/06/2026

Signature with Seal: 
Assistant Ex. Engineer
J&K Jal Shakti Sub-Division
Bhaderwah

Name: G. GOBALSINGH.

Designation: ASSISTANT. EXECUTIVE ENGINEER

Name & Address of the Office / Department: JALSHAKTI (PHE) SUB-DIVISION. BHADERWAH

To
Chairman,
Swiss International School,
Drudhu, Bhaderwah
Distt. Doda, J&K
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Govt. of Jammu & Kashmir

P.H.E. Department Jammu Division Doda

WATER TESTING LABORATORY BHADERWAH

TEST - REPORT

District Name : Doda Tehsil Name: Bhaderwah Block Name: Bhaderwah Panchayat
Name: Drudhu Rev. Village: Drudhu WSS Name: Chunna Seri

Habitation Name: Chunna Source of Scheme: Mullah C Filter Water

Laboratory Name: Water Testing Laboratory Bhaderwah Sample Collected by:

Shahnawaz D.O. Testing: 28-03-2026


Client Name: Swiss International School, Drudu Bhaderwah.


Sample No: 1291

Dated: 30-03-2026

Sl. No.	Parameter Name	Unit of Measurement	BIS Permissible Limit (1991)	BIS Desirable Limit	Actual Level
1	2	3	4	5	6
01	Alkalinity	Mg/l	600	200	74
02	Aluminium	Mg/l	0.2	0.03	-
03	Arsenic	Mg/l	0.05	0.01	-
04	Calcium	Mg/l	200	75	30
05	Chloride	Mg/l	1000	250	00
06	Coli form	(MNP/100ml)	0	0	-
07	Copper	Mg/l	1.5	0.05	-
08	E - Coli (MNP/100ml)	(MNP/100ml)	0	0	Negative
09	Fluoride	Mg/l	1.5	1.0	00
10	Hardness	Mg/l	600	200	128
11	Iron	Mg/l	0.3	0.3	0.0
12	Magnesium	Mg/l	100	30	-
13	Manganese	Mg/l	0.3	0.1	-
14	Nitrate	Mg/l	45	45	0.0
15	pH	pH	8.5	6.5	7.5
16	Residual Chlorine	Mg/l	1	0.2	0.0
17	Sulphates	Mg/l	400	200	-
18	TDS	Mg/l	2000	500	118
19	Turbidity	NTU	5.00	1	09.6

Certified that the water is Fit/Unfit for drinking purpose because of excess of quality parameter at Sl. No. NIL


Shahnawaz
Lab. Assistant,
P.H.E. Water Testing Lab.
Bhaderwah


Ashfaq Hussain,
Chemist,
P.H.E. Water Testing Lab.
Bhaderwah

Govt. of Jammu & Kashmir

P.H.E. Department Jammu Division Doda

WATER TESTING LABORATORY BHADERWAH

TEST-REPORT

District Name : **Doda** Tehsil Name: Bhaderwah Block Name: Bhaderwah Panchayat

Name: Drudhy Rev. Village: Daudhy WSS Name: Chunna Serri

Habitation Name: Chunna Source of Scheme: Nullah (Tap water)

Laboratory Name: **Water Testing Laboratory Bhaderwah** Sample Collected by:

Shahnawaz D.O. Testing: 28/03/2026


Client Name: Swiss International School Drudhy Bhaderwah


Sample No: 1290

Dated: 30-03-2026

Sl. No.	Parameter Name	Unit of Measurement	BIS Permissible Limit (1991)	BIS Desirable Limit	Actual Level
1	2	3	4	5	6
01	Alkalinity	Mg/l	600	200	90
02	Aluminium	Mg/l	0.2	0.03	-
03	Arsenic	Mg/l	0.05	0.01	-
04	Calcium	Mg/l	200	75	24
05	Chloride	Mg/l	1000	250	0.0
06	Coli form	(MNP/100ml)	0	0	-
07	Copper	Mg/l	1.5	0.05	-
08	E - Coli (MNP/100ml)	(MNP/100ml)	0	0	Negative
09	Fluoride	Mg/l	1.5	1.0	0.0
10	Hardness	Mg/l	600	200	130
11	Iron	Mg/l	0.3	0.3	0.0
12	Magnesium	Mg/l	100	30	-
13	Manganese	Mg/l	0.3	0.1	-
14	Nitrate	Mg/l	45	45	0.0
15	pH	pH	8.5	6.5	7.5
16	Residual Chlorine	Mg/l	1	0.2	0.0
17	Sulphates	Mg/l	400	200	-
18	TDS	Mg/l	2000	500	140
19	Turbidity	NTU	5.00	1	1.90

Certified that the water is Fit/Unfit for drinking purpose because of excess of quality parameter at Sl. No. NIL


Shahnawaz
Lab. Assistant,
P.H.E. Water Testing Lab.
Bhaderwah


Ashfaq Hussain,
Chemist,
P.H.E. Water Testing Lab.
Bhaderwah